SAFETY SYSTEM®
YOUR PROTECTOR

TECHNICAL SHEET

Sir Safety System S.p.A. Single-member company
Wholly-owned subsidiary of Sir Holding Srl
Via dei Fornaciai, 9 - Santa Maria degli Angeli
06081 Assisi - Perugia - Italy
Tel.+39 075.8043737 - Fax +39 075.8048686

VAT Nr. IT 03359340548
Viale Europa 74
20090 Cusago Milano
Tel. +39 02.90394575
Fax +39 02.90394441

export@sirsafety.com
www.sirsafety.com

UNI EN ISO 9001:2015
UNI EN ISO 14001:2015
UNI EN ISO 45001:2018

Name: ELECTRO glove class 00	**Code: MA1818E0**	**MA18 SPECIAL PROTECTION GLOVES**

Description

Dielectric glove Class 00
Length: 36 cm
Thickness: mm 0,5 in Natural Latex
Insulation: 2.500 V
Proof test voltage: 2,5 kV
Withstand voltage: 0,5 kV

Supplied in a special polyethylene sealed case.

The product has been designed and manufactured to complywith Regulation (EU) 2016/425 and subsequent amendments.

Category	Colours	Available Sizes
III	YELLOW	In stock: 8 - 11

Quantity/Carton

1

EC Standards

IEC 60903

Acid, Oil, Ozone:R
Resistant to very low temperatures:C

Important Information

Protection against contact with voltage-carrying parts under voltage.

Make sure the garment is in good condition, undamaged and clean before use. Once you become aware of a damage, you should immediately replace it.
We recommend six-monthly voltage test.

Store the gloves in their original sealed case, in a dry place far from the light, at a temperature between 5-35ÁC.

If gloves become soiled with sticky substances or dyes, they shall be rubbed with suitable solvents, without brushes or abrasive paper. Do not use naphtha, gasoline, liquid paraffin, toluene, xylene, etc. Then wash with water at a temperature below 25ÁC and soap and dry thoroughly.

Dexterity

Storage and cleaning